

EPA Site 2 Effluent Test Results

Date	pH	Suspended Solids mg/L	Oils & Grease mg/L	BOD mg/L	Total Nitrogen mg/L	Total Phosphorous mg/L	Faecal Coliforms mg/L
Sep-15							
Oct-15							
Nov-15	8.3	2	0	2	2.41	2.32	6
Dec-15							
Jan-16							
Feb-16	8.26	10	0	<2	1.55	4.01	8
Mar-16							
Apr-16							
May-16	8.4	8	0	<2	1.99	4.15	72
Jun-16							
Jul-16							
Aug-16	8.2	5	0	2	2.61	2.96	1
Mean	8.29	6.25	0.00	2.00	2.14	3.36	21.75
Lowest	8.21	2.00	0.00	2.00	1.55	2.32	1.00
Highest	8.35	10.00	0.00	2.00	2.61	4.15	72.00
Limit	9.0	30.0		20.0			10.0
Times exceed limit							1