

EPA Site 1 Effluent Test Results

				Biochemical Oxygen Demand			
	Phosphorous (total)	pH	Nitrogen (total)	BOD	Oils & Grease	Suspended Solids	Faecal Coliforms
Date	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-22							
Oct-22							
Nov-22	2.56	8.31	1.17	<2	<1	14	58
Dec-22							
Jan-23							
Feb-23	2.37	8.95	1.43	3	<1	27	140
Mar-23							
Apr-23							
May-23	4.95	8.44	1.96	4	<1	19	50
Jun-23							
Jul-23							
Aug-23							
Mean	3.29	8.57	1.52	3.50	#DIV/0!	20.00	82.67
Lowest	2.37	8.31	1.17	3.00	0.00	14.00	50.00
Highest	4.95	8.95	1.96	4.00	0.00	27.00	140.00
Limit		9.0		20.0		30.0	600.0
Times exceed limit							

EPA Site 2 Effluent Test Results

				Biochemical Oxygen Demand			
	Phosphorous (total)	pH	Nitrogen (total)	BOD	Oils & Grease	Suspended Solids	Faecal Coliforms
Date	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-22							
Oct-22							
Nov-22	1.46	8.57	1.07	3	<1	9	<2
Dec-22							
Jan-23							
Feb-23	0.29	8.32	0.14	<2	<1	3	<1
Mar-23							
Apr-23							
May-23	1.24	8.35	0.57	<2	<1	4	1
Jun-23							
Jul-23							
Aug-23							
Mean	1.00	8.41	0.59	3.00	#DIV/0!	5.33	1.00
Lowest	0.29	8.32	0.14	3.00	0.00	3.00	1.00
Highest	1.46	8.57	1.07	3.00	0.00	9.00	1.00
Limit		9.0		20.0		30.0	10.0
Times exceed limit							