

EPA Site 2 Effluent Test Results

Date	Phosphorous (total) mg/L	pH	Nitrogen (total) mg/L	Biochemical Oxygen Demand	Oils & Grease mg/L	Suspended Solids mg/L	Faecal Coliforms mg/L
				BOD mg/L			
Sep-23							
Oct-23							
Nov-23	4.71	8.2	5.85	3	<1	12	2
Dec-23							
Jan-24							
Feb-24							
Mar-24							
Apr-24							
May-24							
Jun-24							
Jul-24							
Aug-24							
Mean	4.71	8.20	5.85	3.00	#DIV/0!	12.00	2.00
Lowest	4.71	8.20	5.85	3.00	0.00	12.00	2.00
Highest	4.71	8.20	5.85	3.00	0.00	12.00	2.00
Limit		9.0		20.0		30.0	10.0
Times exceed limit							

EPA Site 1 Effluent Test Results

Date	Phosphorous (total) mg/L	pH	Nitrogen (total) mg/L	Biochemical Oxygen Demand	Oils & Grease mg/L	Suspended Solids mg/L	Faecal Coliforms mg/L
				BOD mg/L			
Sep-23							
Oct-23							
Nov-23	4.77	8.29	2.59	2	<1	12	24
Dec-23							
Jan-24							
Feb-24							
Mar-24							
Apr-24							
May-24							
Jun-24							
Jul-24							
Aug-24							
Mean	4.77	8.29	2.59	2.00	#DIV/0!	12.00	24.00
Lowest	4.77	8.29	2.59	2.00	0.00	12.00	24.00
Highest	4.77	8.29	2.59	2.00	0.00	12.00	24.00
Limit		9.0		20.0		30.0	600.0
Times exceed limit							