

**EPA Site 1 Effluent Test Results**

Biochemical  
Oxygen Demand

	<b>Phosphorous (total)</b>	<b>pH</b>	<b>Nitrogen (total)</b>	<b>BOD</b>	<b>Oils &amp; Grease</b>	<b>Suspended Solids</b>	<b>Faecal Coliforms</b>
<b>Date</b>	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-21							
Oct-21							
Nov-21	4.89	8.64	3.21	3	<1	9	20
Dec-21							
Jan-22							
Feb-22	3.98	9.11	2.05	2	1	57	50
Mar-22							
Apr-22							
May-22	5.34	7.94	3.72	<2	<1	29	<2
Jun-22							
Jul-22							
Aug-22	4.55	8.13	3.97	<2	<1	13	<2
<b>Mean</b>	<b>4.69</b>	<b>8.46</b>	<b>3.24</b>	<b>2.50</b>	<b>1.00</b>	<b>27.00</b>	<b>35.00</b>
<b>Lowest</b>	<b>3.98</b>	<b>7.94</b>	<b>2.05</b>	<b>2.00</b>	<b>1.00</b>	<b>9.00</b>	<b>20.00</b>
<b>Highest</b>	<b>5.34</b>	<b>9.11</b>	<b>3.97</b>	<b>3.00</b>	<b>1.00</b>	<b>57.00</b>	<b>50.00</b>
<b>Limit</b>		<b>9.0</b>		<b>20.0</b>		<b>30.0</b>	<b>600.0</b>
<b>Times exceed limit</b>							

**EPA Site 2 Effluent Test Results**

Date	Biochemical Oxygen Demand						
	Phosphorous (total) mg/L	pH	Nitrogen (total) mg/L	BOD mg/L	Oils & Grease mg/L	Suspended Solids mg/L	Faecal Coliforms mg/L
Sep-21							
Oct-21							
Nov-21	3.53	8.64	2.41	<2	<1	6	2
Dec-21							
Jan-22							
Feb-22	3.04	9.14	1.58	2	2	28	6
Mar-22							
Apr-22							
May-22	3.04	8.08	2.3	<2	<1	16	<1
Jun-22							
Jul-22							
Aug-22	0.89	8.32	1.02	<2	<1	4	<2
<b>Mean</b>	<b>2.63</b>	<b>8.55</b>	<b>1.83</b>	<b>2.00</b>	<b>2.00</b>	<b>13.50</b>	<b>4.00</b>
<b>Lowest</b>	<b>0.89</b>	<b>8.08</b>	<b>1.02</b>	<b>2.00</b>	<b>2.00</b>	<b>4.00</b>	<b>2.00</b>
<b>Highest</b>	<b>3.53</b>	<b>9.14</b>	<b>2.41</b>	<b>2.00</b>	<b>2.00</b>	<b>28.00</b>	<b>6.00</b>
<b>Limit</b>		<b>9.0</b>		<b>20.0</b>		<b>30.0</b>	<b>10.0</b>
Times exceed limit							