

**EPA Site 1 Effluent Test Results**

	pH	Suspended Solids	Oils & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-21							
Oct-21							
Nov-21	8.64	9	<1	3	3.21	4.89	20
Dec-21							
Jan-22							
Feb-22	9.11	57	1	2	2.05	3.98	50
Mar-22							
Apr-22							
May-22							
Jun-22							
Jul-22							
Aug-22							
Mean	8.88	33.00	1.00	2.50	2.63	4.44	35.00
Lowest	8.64	9.00	1.00	2.00	2.05	3.98	20.00
Highest	9.11	57.00	1.00	3.00	3.21	4.89	50.00
Limit	9.0	30.0		20.0			600.0
Times exceed limit							

**EPA Site 2 Effluent Test Results**

	pH	Suspended Solids	Oils & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-21							
Oct-21							
Nov-21	8.6	6.0	<1	<2	2.4	3.5	2.0
Dec-21							
Jan-22							
Feb-22	9.14	28.00	2.00	2.00	1.58	3.04	6.00
Mar-22							
Apr-22							
May-22							
Jun-22							
Jul-22							
Aug-22							
Mean	8.89	17.00	2.00	2.00	2.00	3.29	4.00
Lowest	8.64	6.00	2.00	2.00	1.58	3.04	2.00
Highest	9.14	28.00	2.00	2.00	2.41	3.53	6.00
Limit	9.0	30.0		20.0			10.0
Times exceed limit							