

EPA Site 1 Effluent Test Results

	pH	Suspended Solids	Oils & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-16							
Oct-16							
Nov-16	8.42	13	0	0	2.99	4.76	0
Dec-16							
Jan-17							
Feb-17	8.9	14	0	3	1.36	4.94	12
Mar-17							
Apr-17							
May-17	8.03	14	0	0	2.77	4.88	60
Jun-17							
Jul-17							
Aug-17							
Mean	8.45	13.67	0.00	1.00	2.37	4.86	24.00
Lowest	8.03	13.00	0.00	0.00	1.36	4.76	0.00
Highest	8.90	14.00	0.00	3.00	2.99	4.94	60.00
Limit	9.0	30.0		20.0			600.0
Times exceed limit							

EPA Site 2 Effluent Test Results

	pH	Suspended Solids	Oils & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-16							
Oct-16							
Nov-16	8.4	7	0	0	1.78	2.77	0
Dec-16							
Jan-17							
Feb-17	8.71	8	0	4	0.86	2.73	8
Mar-17							
Apr-17							
May-17	8.1	11	0	0	1.91	3.25	10
Jun-17							
Jul-17							
Aug-17							
Mean	8.41	8.67	0.00	1.33	1.52	2.92	6.00
Lowest	8.11	7.00	0.00	0.00	0.86	2.73	0.00
Highest	8.71	11.00	0.00	4.00	1.91	3.25	10.00
Limit	9.0	30.0		20.0			10.0
Times exceed limit							