

EPA Site 1 Effluent Test Results

	pH	Suspended Solids	Oils & Grease	BOD	Total Nitrogen	Total Phosphorous
Date		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-17						
Oct-17						
Nov-17	8.45	6	0	0	1.64	4.26
Dec-17						
Jan-18						
Feb-18						
Mar-18						
Apr-18						
May-18						
Jun-18						
Jul-18						
Aug-18						
Mean	8.45	6.00	0.00	0.00	1.64	4.26
Lowest	8.45	6.00	0.00	0.00	1.64	4.26
Highest	8.45	6.00	0.00	0.00	1.64	4.26
Limit	9.0	30.0		20.0		
Times exceed limit						

EPA Site 2 Effluent Test Results

	pH	Suspended Solids	Oils & Grease	BOD	Total Nitrogen	Total Phosphorous
Date		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-17						
Oct-17						
Nov-17	8.5	7	0	0	1.68	4.38
Dec-17						
Jan-18						
Feb-18						
Mar-18						
Apr-18						
May-18						
Jun-18						
Jul-18						
Aug-18						
Mean	8.47	7.00	0.00	0.00	1.68	4.38
Lowest	8.47	7.00	0.00	0.00	1.68	4.38
Highest	8.47	7.00	0.00	0.00	1.68	4.38
Limit	9.0	30.0		20.0		
Times exceed limit						

Faecal Coliforms
mg/L
42
42.00
42.00
42.00
600.0

Faecal Coliforms
mg/L
6
6.00
6.00
6.00
10.0