

EPA Sampling Point 1 Test Results

	PH	Suspended Solids	Oil & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-19	8.61	9	<1	<2	2.87	5.66	4
Oct-19	9.44	26	<1	2	1.59	3.57	40
Nov-19							
Dec-19							
Jan-20							
Feb-20							
Mar-20							
Apr-20							
May-20							
Jun-20							
Jul-20							
Aug-20							
Mean							
Lowest							
Highest							
Limit	6 to 9	30	N/A	20	N/A	N/A	600
Times exceed Limit							

EPA Sampling Point 2 Test Results

	PH	Suspended Solids	Oil & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-19	8.55	<2	<1	<2	1.19	1.85	<2
Oct-19	9.16	10	<1	<2	0.92	1.88	4
Nov-19							
Dec-19							
Jan-20							
Feb-20							
Mar-20							
Apr-20							
May-20							
Jun-20							
Jul-20							
Aug-20							
Mean							
Lowest							
Highest							
Limit	6 to 9	30	N/A	20	N/A	N/A	10
Times exceed Limit							