

### EPA Site 2 Effluent Test Results

Biochemical  
Oxygen  
Demand

	Phosphorous (total)	pH	Nitrogen (total)	BOD	Oils & Grease	Suspended Solids	Faecal Coliforms
Date	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-21							
Oct-21							
Nov-21	3.53	8.64	2.41	<2	<1	6	2
Dec-21							
Jan-22							
Feb-22							
Mar-22							
Apr-22							
May-22							
Jun-22							
Jul-22							
Aug-22							
Mean	3.53	8.64	2.41	#DIV/0!	#DIV/0!	6.00	2.00
Lowest	3.53	8.64	2.41	0.00	0.00	6.00	2.00
Highest	3.53	8.64	2.41	0.00	0.00	6.00	2.00
Limit		9.0		20.0		30.0	10.0
Times exceed limit							

### EPA Site 1 Effluent Test Results

Biochemical  
Oxygen  
Demand

	Phosphorous (total)	pH	Nitrogen (total)	BOD	Oils & Grease	Suspended Solids	Faecal Coliforms
Date	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Sep-21							
Oct-21							
Nov-21	4.89	8.64	3.21	3	<1	9	20
Dec-21							
Jan-22							
Feb-22							
Mar-22							
Apr-22							
May-22							
Jun-22							
Jul-22							
Aug-22							
Mean	4.89	8.64	3.21	3.00	#DIV/0!	9.00	20.00
Lowest	4.89	8.64	3.21	3.00	0.00	9.00	20.00
Highest	4.89	8.64	3.21	3.00	0.00	9.00	20.00
Limit		9.0		20.0		30.0	600.0

Times exceed limit						
--------------------	--	--	--	--	--	--