

EPA Sampling Point 1 Test Results

	PH	Suspended Solids	Oil & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-20							
Oct-20							
Nov-20	8.08	13	<1	<2	2.99	4.39	<2
Dec-20							
Jan-21							
Feb-21	8.27	20	<1	2	2.91	6.31	4
Mar-21							
Apr-21							
May-21							
Jun-21							
Jul-21							
Aug-21							
Mean							
Lowest							
Highest							
Limit	6 to 9	30	N/A	20	N/A	N/A	600
Times exceed Limit							

EPA Sampling Point 2 Test Results

	PH	Suspended Solids	Oil & Grease	BOD	Total Nitrogen	Total Phosphorous	Faecal Coliforms
Date		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Sep-20							
Oct-20							
Nov-20	8.25	10	<1	<2	2.2	3.15	<2
Dec-20							
Jan-21							
Feb-21	8.28	10	<1	<2	1.55	3.88	<2
Mar-21							
Apr-21							
May-21							
Jun-21							
Jul-21							
Aug-21							
Mean							
Lowest							
Highest							
Limit	6 to 9	30	N/A	20	N/A	N/A	10
Times exceed Limit							